



## SPECIFICATIONS

<b>Model</b>	<b>EXL-01592</b>
<b>Damper Control</b>	<b>2 Modulating 2 Floating Point</b>
<b>Sensor Signal</b>	<b>Thermo Anemometer</b>
<b>Accuracy</b>	<b>± (5% + .2m/s)</b>
<b>Input Voltage</b>	<b>24 V AC/DC</b>
<b>Input Power</b>	<b>10 VA</b>
<b>Output Load Max</b>	<b>1.0 Amps</b>
<b>Digital Outputs</b>	<b>5 Relay - 24 VAC/DC</b>
<b>Analog Outputs</b>	<b>0-10 VDC</b>
<b>Comm. Line</b>	<b>BACnet MS/TP</b>

## PART NUMBER:

**EXL-01592 [Options]**

**Options**  
**OA**

## FEATURES

- Energy Management System ready with BACnet communications
- Electronic Thermo Anemometer AirFlow Measurement Station (AFMS)
- Cubic Feet Per Minute (CFM) setpoint control (optional)
- Easy installation and operation
- Stand-alone operation
- Outside Air Temperature (OAT) measurement (optional)
- Outdoor Air Flow Measurement Station

## BACnet Outside Airflow Measurement Station

### Description:

This BACnet Airflow Measuring Station is designed to measure the airflow with four thermo anemometer sensors that are totaled from four individual CFM calculations for each sensor. The duct size and calibration factor for each of four ducts is entered and then the CFM is totaled.

The duct size in Cubic Feet (CF) and calibration factor are entered into BACnet Analog Value (AV) points.

The sensors measure from 30-4000 FPM standard, other ranges / accuracies are available.

The damper can be controlled to maintain the CFM setpoint using the Analog Output (AO) or floating point with 2 Binary Outputs (BO).

The CFM reading is displayed locally on the controller.

Mounting Brackets may be required.

When ordering quantities greater than 30 customized setpoints and additional sequences are available at additional cost, please request a quote for your application.

Relay isolation allows for independent power supply on controlled equipment.

### Options:

- OA Outside Air Temperature OAT measurement



BACnet is a registered trademark of ASHRAE. EXACTLOGIC does not endorse, approve or test products by comparison with ASHRAE standards. Compliance of these products to requirements of ASHRAE Standard 110 is the responsibility of the BACnet International. BTL is a registered trademark of the BTL Testing Laboratory.

